

SF6 Analyzer Comparison Chart



	GASQUIP FLEX 	DILO 3-038R-R303V1 	WIKA GA11 
Sensor Modules for Fast Calibration	Yes	No	No
Pump-Back	Yes	Yes	Yes
Total Weight	50 lbs	53lbs	55 lbs
Touch-Panel	7" Sunlight Readable	7"	7"
Data Export	CSV/Excel	CSV/Excel	CSV/Excel
Adjustable Pass/Fail Values	Yes	Yes	Yes
Hose Evacuation	Yes	Yes	No
Battery	No	Yes	Yes
Sampling Time	Up to 10 Min	Up to 9 Min	Up to 7.5 Min
External Storage Connection	Yes	Yes	Yes
Pump-Back Max Pressure	145 PSI	145 PSI	145 PSI
Inlet Pressure Range	5-500 PSI	5-145 PSI	5-145 PSI
H2O Sensor Accuracy	± 2 °C	± 2 °C	± 2 °C
H2O Sensor Calibration Interval	1 Year	2 Years	2 Years
SF6 Sensor Accuracy	± 0.5 %	± 0.5 %	± 0.5 %
SF6 Sensor Calibration Interval	2 Years	2 Years	2 Years
SO2 Sensor Accuracy	± 2 %	± 2 %	± 2 %
SO2 Sensor Calibration Interval	1 Years	2 Years	2 Years