

SF6 Analyzer Comparison Chart



| | GASQUIP FLEX  | DILO 3-038R-R303V1  | WIKA GA11  |
|-------------------------------------|--|---|---|
| Sensor Modules for Fast Calibration | Yes | No | No |
| Pump-Back | Yes | Yes | Yes |
| Total Weight | 50 lbs | 53lbs | 55 lbs |
| Touch-Panel | 7" Sunlight Readable | 7" | 7" |
| Data Export | CSV/Excel | CSV/Excel | CSV/Excel |
| Adjustable Pass/Fail Values | Yes | Yes | Yes |
| Hose Evacuation | Yes | Yes | No |
| Battery | No | Yes | Yes |
| Sampling Time | 1st Test Up to 12 Min., Subsequent Tests 7 Min. | Up to 9 Min | Up to 7.5 Min |
| Future Proofed For New Gases | Yes | No | No |
| Pump-Back Max Pressure | 145 PSI | 145 PSI | 145 PSI |
| Inlet Pressure Range | 5-500 PSI | 5-145 PSI | 5-145 PSI |
| H2O Sensor Accuracy | ± 2 °C | ± 2 °C | ± 2 °C |
| H2O Sensor Calibration Interval | 1 Year | 2 Years | 2 Years |
| SF6 Sensor Accuracy | ± 0.5 % | ± 0.5 % | ± 0.5 % |
| SF6 Sensor Calibration Interval | 2 Years | 2 Years | 2 Years |
| SO2 Sensor Accuracy | ± 2 % | ± 2 % | ± 2 % |
| SO2 Sensor Calibration Interval | 1 Years | 2 Years | 2 Years |